


<b>Sales Agent:</b> ArcelorMittal Int. North America 1 South Dearborn, 13th floor CHICAGO IL 60603 USA		<b>ArcelorMittal Belval &amp; Differdange</b> Service Gestion Qualité 66, rue de Luxembourg L-4009 Esch/Alzette		 ArcelorMittal
<b>Plant:</b> ArcelorMittal Belval & Differdange Site de Differdange L-4503 Differdange, LUXEMBOURG		<b>Certificate Nr X4181252</b> Delivery note number 4181252 from 22 April 2020		
<b>Our reference :</b> 1700029488 <b>Your reference :</b> 29539 27.02.2020 PLESA ANAHUAC Y CIAS S.A. DE C.V.		<b>PLESA ANAHUAC Y CIAS S.A. DE C.V.</b> <b>AV. VALLE DE LAS ALAMEDAS 66-O</b> <b>54940 COL. SAN FRANCISCO CHILPAN - TU</b> <b>MEXICO</b>		
ASTM A992 - ASTM A572 GR50 FINE GRAIN SILICON KILLED HOT ROLLED AMERICAN WIDE FLANGE BEAMS				
Manufacturer's test certificate acc. to ASTM A 6				
(Empty space)				



Ord.item	Product	Length	Weight	Heat nr	Weight	Bund.	Bars
000001	W 12 X 12 X 87	40' 12.192 mm	9,438 kg	02006	9,438 kg		6

Heat nr	Heat analysis (%)																
	C	Mn	P	S	Si	N	Cu	Ni	Cr	V	Nb	Mo	Ti	CEV	Sn	Nb+V	
	Min	0,50			0,10												
	Max	0,23	1,60	0,035	0,045	0,40	0,60	0,45	0,35	0,150	0,050	0,150		0,45		0,150	
02006		0,06	0,73	0,029	0,020	0,18	0,008	0,40	0,18	0,14	0,007	0,007	0,050	0,001	0,26	0,02	0,014

Heat nr	Tensile test				
	PSI	PSI 200 mm			
	Ys	UTS	El. (%)	Y/U	
	Min	50.000	65.000	18,00	
	Max	65.000			0,85
02006		61.915	74.675	24,00	0,83
02006		62.495	75.400	24,24	0,83

Material melted and manufactured in LUXEMBOURG

Klecker Roberto  
 Porteur de signature spéciale  
  
 ArcelorMittal Belval & Differdange

<b>Sales Agent:</b> ArcelorMittal Int. North America 1 South Dearborn, 13th floor CHICAGO IL 60603 USA		<b>ArcelorMittal Belval &amp; Differdange</b> Service Gestion Qualité 66, rue de Luxembourg L-4009 Esch/Alzette		 ArcelorMittal																	
<b>Plant:</b> ArcelorMittal Belval & Differdange Site de Differdange L-4503 Differdange, LUXEMBOURG		<b>Certificate Nr X4181256</b> Delivery note number 4181256 from 22 April 2020																			
Our reference : 1700029488 Your reference : 29539 27.02.2020 PLESA ANAHUAC Y CIAS S.A. DE C.V.		PLESA ANAHUAC Y CIAS S.A. DE C.V. AV. VALLE DE LAS ALAMEDAS 66-O 54940 COL. SAN FRANCISCO CHILPAN - TU MEXICO																			
ASTM A992 - ASTM A572 GR50 FINE GRAIN SILICON KILLED HOT ROLLED AMERICAN WIDE FLANGE BEAMS																					
Manufacturer's test certificate acc. to ASTM A 6																					
(Empty space)																					
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Ord.item</th> <th>Product</th> <th>Length</th> <th>Weight</th> <th>Heat nr</th> <th>Weight</th> <th>Bund.</th> <th>Bars</th> </tr> </thead> <tbody> <tr> <td>000001</td> <td>W 12 X 12 X 87</td> <td>40' 12.192 mm</td> <td>9,438 kg</td> <td>02006 02007</td> <td>7,865 kg 1,573 kg</td> <td></td> <td>5 1</td> </tr> </tbody> </table>						Ord.item	Product	Length	Weight	Heat nr	Weight	Bund.	Bars	000001	W 12 X 12 X 87	40' 12.192 mm	9,438 kg	02006 02007	7,865 kg 1,573 kg		5 1
Ord.item	Product	Length	Weight	Heat nr	Weight	Bund.	Bars														
000001	W 12 X 12 X 87	40' 12.192 mm	9,438 kg	02006 02007	7,865 kg 1,573 kg		5 1														
<b>Heat nr</b>		<b>Heat analysis (%)</b>																			
		C	Mn	P	S	Si	N	Cu	Ni	Cr	V	Nb	Mo	Ti	CEV	Sn	Nb+V				
<b>Min</b>			0,50			0,10															
<b>Max</b>		0,23	1,60	0,035	0,045	0,40		0,60	0,45	0,35	0,150	0,050	0,150		0,45		0,150				
02006		0,06	0,73	0,029	0,020	0,18	0,008	0,40	0,18	0,14	0,007	0,007	0,050	0,001	0,26	0,02	0,014				
02007		0,07	0,73	0,025	0,017	0,18	0,008	0,37	0,19	0,12	0,007	0,007	0,050	0,001	0,26	0,03	0,014				
<b>Heat nr</b>		<b>Tensile test</b>																			
		PSI	PSI	200 mm																	
		Ys	UTS	El. (%)	Y/U																
<b>Min</b>		50.000	65.000	18,00																	
<b>Max</b>		65.000		0,85																	
02006		61.915	74.675	24,00	0,83																
02006		62.495	75.400	24,24	0,83																
02007		62.930	76.560	24,38	0,82																
02007		63.655	77.285	24,62	0,82																
Material melted and manufactured in LUXEMBOURG																					
Klecker Roberto Porteur de signature spéciale  ArcelorMittal Belval & Differdange																					