


<b>Sales Agent:</b> ArcelorMittal Int. North America 1 South Dearborn, 13th floor CHICAGO IL 60603 USA	<b>ArcelorMittal Belval &amp; Differdange</b> Service Gestion Qualité 66, rue de Luxembourg L-4009 Esch/Alzette	 ArcelorMittal
<b>Plant:</b> ArcelorMittal Belval & Differdange Site de Differdange L-4503 Differdange , LUXEMBOURG	<b>Certificate Nr X4038751</b> Delivery note number 4038751 from 26 July 2019	
Our reference : 1700028493 Your reference : 28499 13.06.2019 PLESA ANAHUAC Y CIAS S.A. DE C.V.	PLESA ANAHUAC Y CIAS S.A. DE C.V. AV. VALLE DE LAS ALAMEDAS 66-O 54940 COL. SAN FRANCISCO CHILPAN - TU MEXICO	
<b>ASTM A992 - ASTM A572 GR50 FINE GRAIN SILICON KILLED          HOT ROLLED AMERICAN WIDE FLANGE BEAMS</b>		
<b>Manufacturer's test certificate acc. to ASTM A 6</b>		

Ord.item	Product	Length	Weight	Heat nr	Weight	Bund.	Bars
000005	W 24 X 12.75 X 146	40' 12.192 mm	5,292 kg	84946	5,292 kg		2

Heat nr	Heat analysis (%)																
	C	Mn	P	S	Si	N	Cu	Ni	Cr	V	Nb	Mo	Ti	CEV	Sn	Nb+V	
	Min	0,50			0,10												
	Max	0,23	1,60	0,035	0,045	0,40	0,60	0,45	0,35	0,150	0,050	0,150		0,45		0,150	
84946		0,06	0,70	0,021	0,017	0,17	0,010	0,30	0,13	0,14	0,006	0,007	0,040	0,001	0,24	0,03	0,013

Heat nr	Tensile test				
	PSI	PSI 200 mm			
	Ys	UTS	EL. (%)	Y/U	
	Min	50.000	65.000	18,00	
	Max	65.000		0,85	
84946		58.870	72.645	24,44	0,81
84946		59.450	73.370	24,69	0,81

Material melted and manufactured in LUXEMBOURG

Klecker Roberto  
 Porteur de signature spéciale  
  
 ArcelorMittal Belval & Differdange