



Industrial de Válvulas, s.a de c.v.
 Av. de la Industria Lote 16
 Fracc. Industrial El Trébol
 C.P. 54600 Tepic, Jalisco
 Estado de México.

NUMERO: 1252/2007
 DATE: 3/01/08

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

- | | |
|-----------|--|
| MSS SP 70 | CAST IRON GATE VALVES, FLANGED AND THREADED ENDS
VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS |
| MSS SP 71 | CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS
VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS |
| MSS SP 85 | CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS
VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS |

PART NBR / CODIGO: EC04DN1MRB
 DESCRIPTION / DESCRIPCION: VHC 4 125 BR A 126 W719F

No. DE SERIE SERIAL No.	07C 15925
FACTURA/INVOICE	V. 5262

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION P.SI TENSIL STRENGTH P.S.I
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:

ASEGURAMIENTO DE CALIDAD