



Industrial de Valvulas, S.A. de C.V.
 Av. de La Industria Lot 16 Fracc. Industrial El Trebol
 Tepozotlan, Estado de Mexico. C.P. 54600

(Numero) Number
 (Fecha) Date

Y075C3159
 08/11/2010

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

(ACCORDING TO EN10204 TYPE 3.1)

ASEGURAMIENTO DE CALIDAD CERTIFICADO DE CUMPLIMIENTO

WE CERTIFY THAT THE PRODUCT LISTED BELOW WAS DESIGNED, MANUFACTURED AND TESTED ACCORDING TO OUR QUALITY SYSTEM AND REQUIREMENTS GIVEN IN ONE OR MORE OF THE FOLLOWING STANDARDS LAST EDITION:

(CERTIFICAMOS QUE EL PRODUCTO LISTADO ABAJO FUE DISEÑADO, FABRICADO Y PROBADO DE ACUERDO CON NUESTRO SISTEMA DE CALIDAD Y CON REQUISITOS ESTABLECIDOS EN UNO O MAS DE LOS SIGUIENTES ESTANDARES ULTIMA EDICIÓN.)

API 598 - VALVE INSPECTION AND TESTING
 API 599 - METAL PLUG VALVES - FLANGED, THREADED AND WELDING
 ANSI B16-10 - FACE TO FACE AND END TO END DIMENSIONS OF VALVES
 ANSI B16-34 - VALVES - FLANGED, THREADED AND WELDING ENDS
 MSS-SP61 - PRESSURE TESTING OF STEEL VALVES

API 6D
 API 600
 ANSI B16-11
 API 602

- PIPELINE VALVES - GATE, PLUG, BALL AND CHECK
 - STEEL GATE VALVES, FLANGED AND WELDING ENDS
 - FORGED FITTINGS, SOCKET - WELDING AND THREADED
 - COMPACT STEEL GATE VALVES - FLANGED, THREADED, WELDING AND EXTENDED - BODY ENDS

Part No. **AC012A08MAB830000Q**
 (Código) **2" Fig. 5206 F UT WCB, API TRIM No.8 830000Q**
 Description **CAST STEEL GATE VALVE 300 CLASS**
 Descripción **(VALVULA COMPUERTA DE ACERO FUNDIDO CLASE 300)**

VALVE WITH LOW EMISSION CONTROL (50 PPM'S MAX.) (VALVULA SUMINISTRADA CON CONTROL DE BAJAS EMISIONES FUGITIVAS (50 PPM'S MAX.))

PRESSURE TEST (PRUEBAS DE PRESION)	SHELL (CASCO)	BACK (SEAT)	SIDE (LADO)	
			1	2
HYDROSTATIC (PSI) (HIDROSTATICA)	1125	1125	NA	NA
PNEUMATIC (PSI) (NEUMATICA)			80	80

MECHANICAL TESTS (PROP. MECANICAS)

CHEMICAL COMPOSITION (%)			COMPOSICIÓN QUIMICA (%)										TENS	YIELD	ELG	RED	BHN		
ITEM (PARTE)	HEAT No. (COLADA)	MATERIAL (ASTM)	C	Mn	P	S	Si	Ni	Cr	Mo	Cu	V	Cb	KPSI CVN@	KPSI 1ST	% 2ND	% 3RD	AVG	
BODY CUERPO	XS613	ASTM A-216/WCB	0.189	0.860	0.033	0.018	0.360	0.034	0.024	0.026	0.064	0.004		76.56	49.01	29	45	164	
BONNET BONETE	XS565	ASTM A-216/WCB	0.211	0.803	0.036	0.016	0.440	0.035	0.048	0.026	0.069	0.003		78.01	46.69	28	46	157	
WEDGE DISCO	XS615	ASTM A-217/CA15	0.090	0.740	0.016	0.017	0.860	0.690	12.560	0.023	0.049	0.012		93.96	70.33	24	46	265	
			Normalized to (Normalizado a) 930				Temper to (Temple a) 650				Cooled in air. (Enfriado en aire.)								
			Normalized to (Normalizado a) 920				Temper to (Temple a) 650				Cooled in air. (Enfriado en aire.)								
			Normalized a (Normalizado to) 955				Temple a (Temper to) 630				Enfriado en aire. (Cooled in air.)								

CERTIFICADO POR: ASEGURAMIENTO DE CALIDAD
 CERTIFIED BY: QUALITY ASSURANCE

Jessica Garcia