

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

ASEGURAMIENTO DE CALIDAD CERTIFICADO DE CUMPLIMIENTO

WE CERTIFY THAT THE PRODUCT LISTED BELOW WAS DESIGNED, MANUFACTURED AND TESTED ACCORDING TO OUR QUALITY SYSTEM AND REQUIREMENTS GIVEN IN ONE OR MORE OF THE FOLLOWING STANDARDS:
(CERTIFICAMOS QUE EL PRODUCTO LISTADO ABAJO FUE DISEÑADO, FABRICADO Y PRABADO DE ACUERDO CON NUESTRO SISTEMA DE CALIDAD Y CON REQUISITOS ESTABLECIDOS EN UNO O MAS DE LOS SIGUIENTES ESTANDARES)

- | | | | |
|-------------|---|-------------|---|
| API 598 | - VALVE INSPECTION AND TESTING | API 6D | - PIPELINE VALVES - GATE, PLUG, BALL ANF CHECK |
| API 599 | - METAL PLUG VALVES - FLANGED, THREADED AND WELDING | API 600 | - STEEL GATE VALVES, FLANGED AND WELDING ENDS |
| ANSI B16-10 | - FACE TO FACE AND END TO END DIMENSIONS OF VALVES | ANSI B16-11 | - FORGED FITTINGS, SOCKET - WELDING AND THREADED |
| ANSI B16-34 | - VALVES - FLANGED, THREADED AND WELDING ENDS | API 602 | - COMPACT STEEL GATE VALVES - FLANGED, THREADED, WELDING AND EXTENDED - BODY ENDS |
| MSS-SP61 | - PRESSURE TESTING OF STEEL VALVES | | |

Part No. AC032A08MAA
(Codigo)
3" Fig. 5206 F UT WCB, API TRIM No.8 8300000
Description
CAST STEEL GATE VALVE
(VALVULA COMPUERTA DE ACERO FUNDIDO)
VALVE WITH LOW EMISSION CONTROL
(VALVULA SUMINISTRADA CON CONTROL DE EMISIONES FUGITIVAS A 50 PPM'S MAX)

PRESSURE TEST (PRUEBAS DE PRESSION)	SHELL (CASCO)	BACK (SEAT)	SIDE (LADO)
			1 2
HYDROSTATIC (PSI) (HIDROSTATICA)	1125	1125	N A N A
PNEUMATIC (PSI) (NEUMATICA)			80 80

MECHANICAL TESTS (PROP. MECANICAS)

CHEMICAL COMPOSITION (%)

ITEM (PARTES)	HEAT No. (COLADA)	MATERIAL (ASTM)	C	Mn	P	S	Si	Ni	Cr	Mo	Cu	V	W	TENS KPSI CNSI	YIELD KPSI IST	ELG %	RED %	BHN AVG
BONNET	WH16981	ASTM A-216/WCB	0.189	0.963	0.030	0.015	0.506	0.028	0.096	0.012	0.050	0.004		76.12	45.24	34	47	153
BONNET	WH16657	ASTM A-216/WCB	0.199	0.982	0.021	0.012	0.469	0.057	0.056	0.021	0.039	0.006		73.37	46.98	32	56	156
CUERPO	WH81348	ASTM A-217/CA15	0.129	0.741	0.026	0.013	0.463	0.100	13.460	0.028	0.021	0.026		100.34	71.63	23	40	300

FACI0-21 REV "2"

CERTIFIED BY:
QUALITY ASSURANCE



Sandra Ruiz