

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

ASEGURAMIENTO DE CALIDAD CERTIFICADO DE CUMPLIMIENTO

WE CERTIFY THAT THE PRODUCT LISTED BELOW WAS DESIGNED, MANUFACTURED AND TESTED ACCORDING TO OUR QUALITY SYSTEM AND REQUIREMENTS GIVEN IN ONE OR MORE OF THE FOLLOWING STANDARDS:
(CERTIFICAMOS QUE EL PRODUCTO LISTADO ABAJO FUE DISEÑADO, FABRICADO Y PROBADO DE ACUERDO CON NUESTRO SISTEMA DE CALIDAD Y CON REQUISITOS ESTABLECIDOS EN UNO O MAS DE LOS SIGUIENTES ESTANDARES.)

- | | | | |
|-------------|---|-------------|---|
| API 598 | - VALVE INSPECTION AND TESTING | API 6D | - PIPELINE VALVES - GATE, PLUG, BALL ANF CHECK |
| API 599 | - METAL PLUG VALVES - FLANGED, THREADED AND WELDING | API 600 | - STEEL GATE VALVES, FLANGED AND WELDING ENDS |
| ANSI B16-10 | - FACE TO FACE AND END TO END DIMENSIONS OF VALVES | ANSI B16-11 | - FORGED FITTINGS, SOCKET - WELDING AND THREADED |
| ANSI B16-34 | - VALVES - FLANGED, THREADED AND WELDING ENDS | API 602 | - COMPACT STEEL GATE VALVES - FLANGED, THREADED, WELDING AND EXTENDED - BODY ENDS |
| MSS-SP61 | - PRESSURE TESTING OF STEEL VALVES | | |

Part No. AC101A12MAB
(Codigo)
Description 10" Fig. 5202 F 3HF WCB, API TRIM No.12 790000M
Descripción CAST STEEL GATE VALVE
(VALVULA COMPUERTA DE ACERO FUNDIDO)
MANUFACTURED TO MET NACE MR-01-75-2003 REQUIREMEN *TS AND LOW FUGITIVE EMISSIONS CONTROL.
(VALVULA SERVICIO NACE MR-01-75 *Y CONTROL DE EMISIONES FUGITIVAS 50 PPM'S)

PRESSURE TEST (PRUEBAS DE PRESION)	SHELL (CASCO)	BACK (SEAT)	SIDE (LADO)	
			1	2
HYDROSTATIC (PSI) (HIDROSTATICA)	450	450	315	315
PNEUMATIC (PSI) (NEUMATICA)			80	80

CHEMICAL COMPOSITION (%)

COMPOSICIÓN QUIMICA (%)

ITEM (PARTE) (CODICIA)	HEAT No. (COLADA)	MATERIAL (ASTM)	C	Mn	P	S	Si	Ni	Cr	Mo	Cu	V	W	TENS KPSI CNSIG	YIELD KPSI 1ST	ELG %	RED %	BHN AVG
BONNET BONETE	WH19173	ASTM A-216/WCB	0.199	0.985	0.024	0.013	0.471	0.048	0.058	0.013	0.030	0.001		78.59	49.01	30	55	150
BODY CUERPO	WH22311	ASTM A-216/WCB	0.200	0.933	0.017	0.019	Tempor to (Temple a) 930 °C 0.522	0.024	0.045	0.024	0.038	0.005		74.82	48.43	27	49	168
WEDGE DISCO	WH21322	ASTM A-216/WCB	0.190	0.963	0.030	0.019	Tempor to (Temple a) 650 °C 0.455	0.041	0.041	0.022	0.015	0.004		80.91	46.11	31	54	156

MECHANICAL TESTS (PROP. MECANICAS)