

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

(ACCORDING TO EN10204 TYPE 3.1)
 ASEGURAMIENTO DE CALIDAD CERTIFICADO DE CUMPLIMIENTO

WE CERTIFY THAT THE PRODUCT LISTED BELOW WAS DESIGNED, MANUFACTURED AND TESTED ACCORDING TO OUR QUALITY SYSTEM AND REQUIREMENTS GIVEN IN ONE OR MORE OF THE FOLLOWING STANDARDS LAST EDITION:

(CERTIFICAMOS QUE EL PRODUCTO LISTADO ABAJO FUE DISEÑADO, FABRICADO Y PRABADO DE ACUERDO CON NUESTRO SISTEMA DE CALIDAD Y CON REQUISITOS ESTABLECIDOS EN UNO O MAS DE LOS SIGUIENTES ESTANDARES ULTIMA EDICIÓN.)

- API 598 - VALVE INSPECTION AND TESTING
- API 599 - METAL PLUG VALVES - FLANGED, THREADED AND WELDING
- ANSI B16-10 - FACE TO FACE AND END TO END DIMENSIONS OF VALVES
- ANSI B16-34 - VALVES - FLANGED, THREADED AND WELDING ENDS
- MSS-SP61 - PRESSURE TESTING OF STEEL VALVES

- API 6D - PIPELINE VALVES - GATE, PLUG, BALL AND CHECK
- API 600 - STEEL GATE VALVES, FLANGED AND WELDING ENDS
- ANSI B16-11 - FORGED FITTINGS, SOCKET - WELDING AND THREADED
- API 602 - COMPACT STEEL GATE VALVES - FLANGED, THREADED, WELDING AND EXTENDED - BODY ENDS

Part No. AR061A08MAB830000G
 (Código) **6" Fig. 5341 F UT WCB, API TRIM No.8 830000G**
Description CAST STEEL SWING CHECK VALVE 150 PSI
Descripción (VALVULA RETENCIÓN TIPO COLUMPIO DE ACERO FUNDIDO 150 PSI)

VALVE WITH LOW EMISSION CONTROL (VALVULA SUMINISTRADA CON CONTROL DE EMISIONES FUGITIVAS A 50 PPM'S MAX)

PRESSURE TEST (PRUEBAS DE PRESION)	SHELL (CASCO)	BACK (SEAT)	SIDE (LADO)	
			1	2
HYDROSTATIC (PSI) (HIDROSTATICA)	450	N A	315	N A
PNEUMATIC (PSI) (NEUMATICA)			N A	N A

MECHANICAL TESTS (PROP. MECANICAS)

CHEMICAL COMPOSITION (%)

COMPOSICIÓN QUIMICA (%)

TENS YIELD ELG RED BHN

ITEM (PARTE)	HEAT No. (COLADA)	MATERIAL (ASTM)	CHEMICAL COMPOSITION (%)										TENS KPSI CVN@	YIELD KPSI 1ST	ELG % 2ND	RED % 3RD	BHN AVG
			C	Mn	P	S	Si	Ni	Cr	Mo	Cu	V					
BODY CUERPO	12832	ASTM A-216/WCB	0.190	0.690	0.022	0.021	0.380	0.050	0.060	0.080	0.040	0.010	75.98	40.60	34	42	162
COVER TAPA	12831	ASTM A-216/WCB	Normalized to (Normalizado a) 920 °C		0.220 0.730 0.017 0.018		Temper to (Temple a) 650 °C		Cooled in air.(Cooled in air. (Enfr)		0.070 0.030 0.010		74.67	40.02	32	46	156
WEDGE DISCO	12838	ASTM A-216/WCB	Normalized to (Normalizado a) 920 °C		0.180 0.740 0.018 0.017		Temper to (Temple a) 650 °C		Cooled in air.(Cooled in air. (Enfr)		0.070 0.030 0.010		73.51	41.18	30	39	153
			Normalized to (Normalizado a) 920 °C				Temper to (Temple a) 650 °C		Cooled in air.(Cooled in air. (Enfr)								

PLEASA ANAHUAC Y CIAS. S.A. DE C.V.
CONTROL DE CALIDAD
 FECHA 18/Dic/2009
 FIRMA CE000004
 Franque Ruiz


SANDRA RUIZ