

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

ASEGURAMIENTO DE CALIDAD CERTIFICADO DE CUMPLIMIENTO

WE CERTIFY THAT THE PRODUCT LISTED BELOW WAS DESIGNED, MANUFACTURED AND TESTED ACCORDING TO OUR QUALITY SYSTEM AND REQUIREMENTS GIVEN IN ONE OR MORE OF THE FOLLOWING STANDARDS:
 (CERTIFICAMOS QUE EL PRODUCTO LISTADO ABAJO FUE DISEÑADO, FABRICADO Y PRABADO DE ACUERDO CON NUESTRO SISTEMA DE CALIDAD Y CON REQUISITOS ESTABLECIDOS EN UNO O MAS DE LOS SIGUIENTES ESTANDARES.)

- | | | | |
|-------------|---|-------------|---|
| API 598 | - VALVE INSPECTION AND TESTING | API 6D | - PIPELINE VALVES - GATE, PLUG, BALL ANF CHECK |
| API 599 | - METAL PLUG VALVES - FLANGED, THREADED AND WELDING | API 600 | - STEEL GATE VALVES, FLANGED AND WELDING ENDS |
| ANSI B16-10 | - FACE TO FACE AND END TO END DIMENSIONS OF VALVES | ANSI B16-11 | - FORGED FITTINGS, SOCKET - WELDING AND THREADED |
| ANSI B16-34 | - VALVES - FLANGED, THREADED AND WELDING ENDS | API 602 | - COMPACT STEEL GATE VALVES - FLANGED, THREADED, WELDING AND EXTENDED - BODY ENDS |
| MSS-SP61 | - PRESSURE TESTING OF STEEL VALVES | | |

Part No. AC032A08MAB
 (Código)
3" Fig. 5206 F UT WCB, API TRIM No.8 830000K
Description
 CAST STEEL GATE VALVE
 (VALVULA COMPUERTA DE ACERO FUNDIDO)
 VALVE WITH LOW EMISSION CONTROL
 (VALVULA SUMINISTRADA CON CONTROL DE EMISIONES FUGITIVAS A 50 PPM'S MAX)

PRESSURE TEST (PRUEBAS DE PRESION)	SHELL (CASCO)	BACK (SEAT)	SIDE (LADO)
HYDROSTATIC (PSI) (HIDROSTATICA)	1125	1125	N A N A
PNEUMATIC (PSI) (NEUMATICA)			80 80

MECHANICAL TESTS (PROP. MECANICAS)			
TENS	YIELD	ELG	RED BHN
KPSI CVN@	KPSI 1ST	% 2ND	% 3RD AVG
78.88	49.01	33	57 159
75.40	47.56	34	48 157
99.18	69.74	25	47 269

CHEMICAL COMPOSITION (%)													
COMPOSICIÓN QUIMICA (%)													
C	Mn	P	S	Si	Ni	Cr	Mo	Cu	V	Cb			
0.198	0.940	0.024	0.013	0.473	0.040	0.035	0.021	0.011	0.003				
Normalized to (Normalizado a) 920 °C													
0.188	0.974	0.025	0.018	0.532	0.045	0.045	0.014	0.016	0.003				
Normalized to (Normalizado a) 920 °C													
0.100	#####	0.017	0.010	0.850	0.280	12.170	0.018	0.042	0.002				
Normalized to (Normalizado to) 970 °C													
Temple a (Temper to) 630 °C													
Enfriado en aire. (Enfriado en aire. (C)													


Sandra Ruiz