

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

ASEGURAMIENTO DE CALIDAD CERTIFICADO DE CUMPLIMIENTO

WE CERTIFY THAT THE PRODUCT LISTED BELOW WAS DESIGNED, MANUFACTURED AND TESTED ACCORDING TO OUR QUALITY SYSTEM AND REQUIREMENTS GIVEN IN ONE OR MORE OF THE FOLLOWING STANDARDS:
 (CERTIFICAMOS QUE EL PRODUCTO LISTADO ABAJO FUE DISEÑADO, FABRICADO Y PROBADO DE ACUERDO CON NUESTRO SISTEMA DE CALIDAD Y CON REQUISITOS ESTABLECIDOS EN UNO O MAS DE LOS SIGUIENTES ESTANDARES.)

- | | | | |
|-------------|---|-------------|---|
| API 598 | - VALVE INSPECTION AND TESTING | API 6D | - PIPELINE VALVES - GATE, PLUG, BALL ANF CHECK |
| API 599 | - METAL PLUG VALVES - FLANGED, THREADED AND WELDING | API 600 | - STEEL GATE VALVES, FLANGED AND WELDING ENDS |
| ANSI B16-10 | - FACE TO FACE AND END TO END DIMENSIONS OF VALVES | ANSI B16-11 | - FORGED FITTINGS, SOCKET - WELDING AND THREADED |
| ANSI B16-34 | - VALVES - FLANGED, THREADED AND WELDING ENDS | API 602 | - COMPACT STEEL GATE VALVES - FLANGED, THREADED, WELDING AND EXTENDED - BODY ENDS |
| MSS-SP61 | - PRESSURE TESTING OF STEEL VALVES | | |

Part No. **AC032A08MAB**

(Código) **3" Fig. 5206 F UT WCB, API TRIM No.8 830000K**

Description **CAST STEEL GATE VALVE**
(VALVULA COMPUERTA DE ACERO FUNDIDO)
 VALVE WITH LOW EMISSION CONTROL
 (VALVULA SUMINISTRADA CON CONTROL DE EMISIONES FUGITIVAS A 50 PPM'S MAX)

PRESSURE TEST (PRUEBAS DE PRESION)	SHELL (CASCO)	BACK (SEAT)	SIDE (LADO)
HYDROSTATIC (PSD) (HIDROSTATICA)	1125	1125	N A N A
PNEUMATIC (PSD) (NEUMATICA)			80 80

MECHANICAL TESTS (PROP. MECANICAS)

ITEM (PARTE)	HEAT No. (COLADA)	MATERIAL (ASTM)	CHEMICAL COMPOSITION (%)										MECHANICAL TESTS (PROP. MECANICAS)				
			C	Min	P	S	Si	Ni	Cr	Mo	Cu	V	Cb	TENS KPSI (Kg)	YIELD KPSI 1ST	ELG % 2ND	RED % 3RD
BONNET	WH22731	ASTM A-216/WCB	0.200	0.891	0.023	0.019	0.431	0.020	0.010	0.030	0.020	0.001	76.70	45.24	30	47	167
BONETE			Normalized to (Normalized a) 930 °C Temper to (Temple a) 650 °C														
BODY	WH19453	ASTM A-216/WCB	0.203	0.942	0.026	0.017	0.543	0.052	0.045	0.018	0.022	0.002	75.26	53.22	34	54	156
CUERPO			Normalized to (Normalized a) 920 °C Temper to (Temple a) 650 °C														
WEDGE	D5398	ASTM A-217/CA15	0.100	0.850	0.027	0.016	0.880	0.088	12.670	0.063	0.045	0.002	100.63	68.73	26	46	275
DISCO			Normalized a (Normalized to) 970 °C Temple a (Temper to) 630 °C														

CERTIFICADO POR: **Sandra Ruiz**
 ASEGURAMIENTO DE CALIDAD
 QUALITY ASSURANCE