



Industrial de Valvulas, S.A de C.V.
 Av. de La Industria Lote 16 Fracc. Industrial El Trebol
 Tepic, Jalisco, Estado de Mexico C.P. 54600

(Numero) Number V08C11036
 (Fecha) Date 01/02/2008

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

ASEGURAMIENTO DE CALIDAD CERTIFICADO DE CUMPLIMIENTO

WE CERTIFY THAT THE PRODUCT LISTED BELOW WAS DESIGNED, MANUFACTURED AND TESTED ACCORDING TO OUR QUALITY SYSTEM AND REQUIREMENTS GIVEN IN ONE OR MORE OF THE FOLLOWING STANDARDS:
 (CERTIFICAMOS QUE EL PRODUCTO LISTADO ABAJO FUE DISEÑADO, FABRICADO Y PROBADO DE ACUERDO CON NUESTRO SISTEMA DE CALIDAD Y CON REQUISITOS ESTABLECIDOS EN UNO O MAS DE LOS SIGUIENTES ESTANDARES.)

- VALVE INSPECTION AND TESTING
- METAL PLUG VALVES - FLANGED, THREADED AND WELDING
- FACE TO FACE AND END TO END DIMENSIONS OF VALVES
- VALVES - FLANGED, THREADED AND WELDING ENDS
- PRESSURE TESTING OF STEEL VALVES
- PIPELINE VALVES - GATE, PLUG, BALL ANF CHECK
- STEEL GATE VALVES, FLANGED AND WELDING ENDS
- FORGED FITTINGS, SOCKET - WELDING AND THREADED
- COMPACT STEEL GATE VALVES - FLANGED, THREADED, WELDING AND EXTENDED - BODY ENDS

Part No. **AC022A08MAB**

(Codigo) **2 1/2" Fig. 5206 F UT WCB, API TRIM No.8 830000M**

Description **CAST STEEL GATE VALVE**
(VALVULA COMPUERTA DE ACERO FUNDIDO)

VALVE WITH LOW EMISSION CONTROL
 (VALVULA SUMINISTRADA CON CONTROL DE EMISIONES FUGITIVAS A 50 PPM'S MAX)

PRESSURE TEST (PRUEBAS DE PRESION)	SHELL (CASCO)	BACK (SEAT)	SIDE (LADO)	
			1	2
HYDROSTATIC (PSI) (HIDROSTATICA)	1125	1125	N A	N A
PNEUMATIC (PSI) (NEUMATICA)			80	80

CHEMICAL COMPOSITION (%)	COMPOSICIÓN QUIMICA (%)										MECHANICAL TESTS (PROP. MECANICAS)				
	C	Mn	P	S	SI	NI	Cr	Mo	Cu	V	Cb	TENS KPSI CVN/60	YIELD KPSI 1ST	ELG %	RED %

ITEM (PARTE)	HEAT No. (COLADN)	MATERIAL (ASTM)																
BONNET	WH17093	ASTM A-216/WCB	0.188	0.979	0.025	0.020	0.425	0.043	0.043	0.015	0.005	0.001	83.52	41.47	31	62	160	
BOINTE			Normalized to (Normalizado a) 920 °C															
BODY	WH19891	ASTM A-216/WCB	0.206	0.880	0.029	0.023	0.478	0.040	0.061	0.024	0.018	0.004	74.39	42.92	34	53	160	
CUERPO			Normalized to (Normalizado a) 920 °C															
WEDGE	D3623	ASTM A-217/CA15	0.130	0.790	0.029	0.012	0.960	0.840	12.510	0.025	0.025	0.001	99.47	70.04	25	47	274	
DISCO			Normalized to (Normalizado a) 970 °C															
			Temple a (Temper to) 630 °C															
			Enfriado en aire (Enfriado en aire. (C))															

FAC10-21 REV 72

CERTIFICADO POR
 ASEGURAMIENTO DE CALIDAD

CERTIFIED BY:

 Sandra Ruiz

QUALITY ASSURANCE