

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

(ACCORDING TO EN10204 TYPE 3.1)

ASEGURAMIENTO DE CALIDAD CERTIFICADO DE CUMPLIMIENTO

WE CERTIFY THAT THE PRODUCT LISTED BELOW WAS DESIGNED, MANUFACTURED AND TESTED ACCORDING TO OUR QUALITY SYSTEM AND REQUIREMENTS GIVEN IN ONE OR MORE OF THE FOLLOWING STANDARDS LAST EDITION:

(CERTIFICAMOS QUE EL PRODUCTO LISTADO ABAJO FUE DISEÑADO, FABRICADO Y PRABADO DE ACUERDO CON NUESTRO SISTEMA DE CALIDAD Y CON REQUISITOS ESTABLECIDOS EN UNO O MAS DE LOS SIGUIENTES ESTANDARES ULTIMA EDICIÓN.)

- | | | | |
|-------------|---|-------------|---|
| API 598 | - VALVE INSPECTION AND TESTING | API 6D | - PIPELINE VALVES - GATE, PLUG, BALL AND CHECK |
| API 599 | - METAL PLUG VALVES - FLANGED, THREADED AND WELDING | API 600 | - STEEL GATE VALVES, FLANGED AND WELDING ENDS |
| ANSI B16-10 | - FACE TO FACE AND END TO END DIMENSIONS OF VALVES | ANSI B16-11 | - FORGED FITTINGS, SOCKET - WELDING AND THREADED |
| ANSI B16-34 | - VALVES - FLANGED, THREADED AND WELDING ENDS | API 602 | - COMPACT STEEL GATE VALVES - FLANGED, THREADED, WELDING AND EXTENDED - BODY ENDS |
| MSS-SP61 | - PRESSURE TESTING OF STEEL VALVES | | |

Part No. AR081A08MAB830000C

(Código)

Description 8" Fig. 5341 F UT WCB, API TRIM No.8 830000C
Descripción CAST STEEL SWING CHECK VALVE 150 CLASS (VALVULA RETENCIÓN TIPO COLUMPIO DE ACERO FUNDIDO 150 CLASS)
VALVE WITH LOW EMISSION CONTROL (VALVULA SUMINISTRADA CON CONTROL DE EMISIONES FUGITIVAS A 50 PPM'S MAX)

PRESSURE TEST (PRUEBAS DE PRESION)	SHELL (CASCO)	BACK (SEAT)	SIDE (LADO)	
			1	2
HYDROSTATIC (PSD) (HIDROSTATICA)	450	N A	315	N A
PNEUMATIC (PSD) (NEUMATICA)			N A	N A

MECHANICAL TESTS (PROP. MECANICAS)
CHEMICAL COMPOSITION (%)
COMPOSICIÓN QUIMICA (%)
TENS YIELD ELG RED BHN

ITEM (PARTE)	HEAT No. (COLADA)	MATERIAL (ASTM)	C	Mn	P	S	Si	Ni	Cr	Mo	Cu	V	Cb	KPSI	KPSI	%	%	AVG
														CVN@	IST	2ND	3RD	
BODY CUERPO	WH69028	ASTM A-216/WCB	0.216	0.887	0.028	0.016	0.425	0.041	0.027	0.007	0.006	0.009		75.40	43.21	28	50	154
Normalizated to (Normalizado a) 930 °C													Temper to (Temple a) 650 °C			Cooled in air.(Cooled in air. (Enfr)		
COVER TAPA	WH30914	ASTM A-216/WCB	0.216	0.890	0.031	0.021	0.441	0.060	0.088	0.005	0.036	0.001		76.27	45.53	27	47	166
Normalizated to (Normalizado a) 930 °C													Temper to (Temple a) 650 °C			Cooled in air.(Cooled in air. (Enfr)		
WEDGE DISCO	WH82001	ASTM A-217/CA15	0.136	0.730	0.028	0.014	0.540	0.124	12.310	0.036	0.032	0.023		101.36	71.20	22	40	297
Normalizado a (Normalizado to) 955 °C													Temple a (Temper to) 630 °C			Enfriado en aire.(Enfriado en airc. (C)		

PLEASA ANAHUAC Y CIAS. S.A. DE C.V.
CONTROL DE CALIDAD
 FECHA: 28 Feb 2010
 C0000223
 FICHA: Enrique Ruiz


JESSICA GARCIA