

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

(ACCORDING TO EN10204 TYPE 3.1)

ASEGURAMIENTO DE CALIDAD CERTIFICADO DE CUMPLIMIENTO

WE CERTIFY THAT THE PRODUCT LISTED BELOW WAS DESIGNED, MANUFACTURED AND TESTED ACCORDING TO OUR QUALITY SYSTEM AND REQUIREMENTS GIVEN IN ONE OR MORE OF THE FOLLOWING STANDARDS LAST EDITION:

(CERTIFICAMOS QUE EL PRODUCTO LISTADO ABAJO FUE DISEÑADO, FABRICADO Y PROBADO DE ACUERDO CON NUESTRO SISTEMA DE CALIDAD Y CON REQUISITOS ESTABLECIDOS EN UNO O MAS DE LOS SIGUIENTES ESTANDARES ULTIMA EDICIÓN.)

- | | | | |
|-------------|---|-------------|---|
| API 598 | - VALVE INSPECTION AND TESTING | API 6D | - PIPELINE VALVES - GATE, PLUG, BALL AND CHECK |
| API 599 | - METAL PLUG VALVES - FLANGED, THREADED AND WELDING | API 600 | - STEEL GATE VALVES, FLANGED AND WELDING ENDS |
| ANSI B16-10 | - FACE TO FACE AND END TO END DIMENSIONS OF VALVES | ANSI B16-11 | - FORGED FITTINGS, SOCKET - WELDING AND THREADED |
| ANSI B16-34 | - VALVES - FLANGED, THREADED AND WELDING ENDS | API 602 | - COMPACT STEEL GATE VALVES - FLANGED, THREADED, WELDING AND EXTENDED - BODY ENDS |
| MSS-SP61 | - PRESSURE TESTING OF STEEL VALVES | | |

Part No. **AC011A08MAA8300000**

(Código) **2" Fig. 5202 F UT WCB, API TRIM No.8 8300000**

Descripción **CAST STEEL GATE VALVE 150 CLASS
 (VALVULA COMPUERTA DE ACERO FUNDIDO CLASE 150)**

VALVE WITH LOW EMISSION CONTROL (VALVULA SUMINISTRADA CON CONTROL DE EMISIONES FUGITIVAS A 50 PPM'S MAX)

PRESSURE TEST (PRUEBAS DE PRESION)	SHELL (CASCO)	BACK (SEAT)	SIDE (LADO)	
			1	2
HYDROSTATIC (PSI) (HIDROSTATICA)	450	450	N A	N A
PNEUMATIC (PSI) (NEUMATICA)			80	80

MECHANICAL TESTS (PROP. MECANICAS)

CHEMICAL COMPOSITION (%)

COMPOSICIÓN QUIMICA (%)

TENS YIELD ELG RED BHN

ITEM (PARTE)	HEAT No. (COLADA)	MATERIAL (ASTM)	CHEMICAL COMPOSITION (%)										MECHANICAL TESTS				
			C	Mn	P	S	Si	Ni	Cr	Mo	Cu	V	Cb	KPSI CVN@	KPSI 1ST	% 2ND	% 3RD
BODY CUERPO	WH24914	ASTM A-216/WCB	0.199	0.919	0.031	0.018	0.488	0.007	0.033	0.010	0.028	0.005	83.81	52.78	30	54	157
Normalized to (Normalizado a) 930 °C			Temper to (Temple a) 650 °C										Cooled in air.(Enfriado en aire. (C))				
BONNET BONETE	WH16306	ASTM A-216/WCB	0.217	0.965	0.024	0.012	0.509	0.044	0.010	0.038	0.019	0.005	84.53	45.09	31	45	159
Normalized to (Normalizado a) 930 °C			Temper to (Temple a) 630 °C										Cooled in air.(Enfriado en aire. (C))				
WEDGE DISCO	WH81290	ASTM A-217/CA15	0.132	0.732	0.037	0.021	0.711	0.107	13.250	0.021	0.018	0.023	99.62	71.63	27	39	300
Normalized a (Normalizado to) 970 °C			Temple a (Temple to) 630 °C										Enfriado en aire.(Enfriado en aire. (C))				

PLEASE ANAHUAC Y CIA.S. S.A. DE C.V.

CONTROL DE CALIDAD

FECHA 12 May 2010

1822

FIRMA E. RUIZ

FACIO-21 REV "3"

CERTIFICADO POR:
 ASEGURAMIENTO DE CALIDAD

CERTIFIED BY :
 QUALITY ASSURANCE

JESSICA GARCIA