

## QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

(ACCORDING TO EN10204 TYPE 3.1)  
ASEGURAMIENTO DE CALIDAD CERTIFICADO DE CUMPLIMIENTO

WE CERTIFY THAT THE PRODUCT LISTED BELOW WAS DESIGNED, MANUFACTURED AND TESTED ACCORDING TO OUR QUALITY SYSTEM AND REQUIREMENTS GIVEN IN ONE OR MORE OF THE FOLLOWING STANDARDS LAST EDITION:

(CERTIFICAMOS QUE EL PRODUCTO LISTADO ABAJO FUE DISEÑADO, FABRICADO Y PRABADO DE ACUERDO CON NUESTRO SISTEMA DE CALIDAD Y CON REQUISITOS ESTABLECIDOS EN UNO O MAS DE LOS SIGUIENTES ESTANDARES ULTIMA EDICIÓN.)

API 598 - VALVE INSPECTION AND TESTING  
API 599 - METAL PLUG VALVES - FLANGED, THREADED AND WELDING  
ANSI B16-10 - FACE TO FACE AND END TO END DIMENSIONS OF VALVES  
ANSI B16-34 - VALVES - FLANGED, THREADED AND WELDING ENDS  
MSS-SP61 - PRESSURE TESTING OF STEEL VALVES

API 6D  
API 600  
ANSI B16-11  
API 602

- PIPELINE VALVES - GATE, PLUG, BALL AND CHECK  
- STEEL GATE VALVES, FLANGED AND WELDING ENDS  
- FORGED FITTINGS, SOCKET - WELDING AND THREADED  
- COMPACT STEEL GATE VALVES - FLANGED, THREADED, WELDING AND EXTENDED - BODY ENDS

Part No. **AC011A08MAA8300000**  
(Código) **2" Fig. 5202 F UT WCB, API TRIM No.8 8300000**  
Description **CAST STEEL GATE VALVE 150 CLASS**  
Descripción **(VALVULA COMPUERTA DE ACERO FUNDIDO CLASE 150)**

VALVE WITH LOW EMISSION CONTROL (VALVULA SUMINISTRADA CON CONTROL DE EMISIONES FUGITIVAS A 50 PPM'S MAX )

PRESSURE TEST (PRUEBAS DE PRESION)	SHELL (CASCO)	BACK (SEAT)	SIDE (LADO)	
			1	2
HYDROSTATIC (PSI) (HIDROSTATICA)	450	450	N A	N A
PNEUMATIC (PSI) (NEUMATICA)			80	80

### MECHANICAL TESTS (PROP. MECANICAS)

### CHEMICAL COMPOSITION (%)

### COMPOSICIÓN QUIMICA (%)

### TENS YIELD ELG RED BHN

ITEM (PARTE)	HEAT No. (COLADA)	MATERIAL (ASTM)	C	Mn	P	S	Si	Ni	Cr	Mo	Cu	V	Cb	KPSI CVN@	KPSI 1ST	% 2ND	% 3RD	AVG
<b>BODY</b> CUERPO	WH19576	ASTM A-216/WCB	0.200	0.896	0.014	0.007	0.408	0.040	0.069	0.025	0.020	0.004		72.07	37.27	34	54	158
<b>BONNET</b> BONETE	WH6674	ASTM A-216/WCB	Normalized to (Normalizado a) 930				Temper to (Temple a) 650			Cooled in air. (Enfriado en aire.)				73.66	46.11	29	49	163
<b>WEDGE</b> DISCO	D2568	ASTM A-217/CA15	0.192	0.952	0.023	0.026	0.510	0.030	0.040	0.020	0.040	0.001		100.77	68.29	25	48	269
			Normalized to (Normalizado a) 930				Temper to (Temple a) 650			Cooled in air. (Enfriado en aire.)								
			0.140	0.860	0.026	0.012	0.950	0.500	12.140	0.017	0.090	0.001						
			Normalizado a (Normalizado to) 970				Temple a (Temper to) 630			Enfriado en aire. (Cooled in air.)								

FAC10-21 REV "3"

CERTIFICADO POR:  
ASEGURAMIENTO DE CALIDAD

CERTIFIED BY :  
QUALITY ASSURANCE

  
Jessica Garcia