

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

(ACCORDING TO EN10204 TYPE 3.1)
ASEGURAMIENTO DE CALIDAD CERTIFICADO DE CUMPLIMIENTO

WE CERTIFY THAT THE PRODUCT LISTED BELOW WAS DESIGNED, MANUFACTURED AND TESTED ACCORDING TO OUR QUALITY SYSTEM AND REQUIREMENTS GIVEN IN ONE OR MORE OF THE FOLLOWING STANDARDS LAST EDITION:

(CERTIFICAMOS QUE EL PRODUCTO LISTADO ABAJO FUE DISEÑADO, FABRICADO Y PRABADO DE ACUERDO CON NUESTRO SISTEMA DE CALIDAD Y CON REQUISITOS ESTABLECIDOS EN UNO O MAS DE LOS SIGUIENTES ESTANDARES ULTIMA EDICIÓN.)

- | | | | |
|-------------|---|-------------|---|
| API 598 | - VALVE INSPECTION AND TESTING | API 6D | - PIPELINE VALVES - GATE, PLUG, BALL AND CHECK |
| API 599 | - METAL PLUG VALVES - FLANGED, THREADED AND WELDING | API 600 | - STEEL GATE VALVES, FLANGED AND WELDING ENDS |
| ANSI B16-10 | - FACE TO FACE AND END TO END DIMENSIONS OF VALVES | ANSI B16-11 | - FORGED FITTINGS, SOCKET - WELDING AND THREADED |
| ANSI B16-34 | - VALVES - FLANGED, THREADED AND WELDING ENDS | API 602 | - COMPACT STEEL GATE VALVES - FLANGED, THREADED, WELDING AND EXTENDED - BODY ENDS |
| MSS-SP61 | - PRESSURE TESTING OF STEEL VALVES | | |

Part No. AC081A08MAA8300000
(Código) **8" Fig. 5202 F UT WCB, API TRIM No.8 8300000**
Description

Descripción **CAST STEEL GATE VALVE 150 CLASS**
(VALVULA COMPUERTA DE ACERO FUNDIDO 150 CLASS)

VALVE WITH LOW EMISSION CONTROL (VALVULA SUMINISTRADA CON CONTROL DE EMISIONES FUGITIVAS A 50 PPM'S MAX)


PRESSURE TEST (PRUEBAS DE PRESION)	SHELL (CASCO)	BACK (SEAT)	SIDE (LADO)	
			1	2
HYDROSTATIC (PSI) (HIDROSTATICA)	450	450	315	315
PNEUMATIC (PSI) (NEUMATICA)			80	80

MECHANICAL TESTS (PROP. MECANICAS)

CHEMICAL COMPOSITION (%)												COMPOSICIÓN QUIMICA (%)					TENS	YIELD	ELG	RED	BHN
ITEM (PARTE)	HEAT No. (COLADA)	MATERIAL (ASTM)	C	Mn	P	S	Si	Ni	Cr	Mo	Cu	V	Cb	KPSI CVN@	KPSI 1ST	% 2ND	% 3RD	AVG			

BODY CUERPO	WH31680	ASTM A-216/WCB	0.215	0.940	0.031	0.017	0.417	0.040	0.036	0.032	0.001	0.001		75.40	43.21	28	50	165
Normalized to (Normalizado a) 930 °C			Temper to (Temple a) 650 °C			Cooled in air. (Cooled in air. (Enfri												
BONNET BONETE	WH31979	ASTM A-216/WCB	0.203	0.890	0.029	0.016	0.456	0.051	0.079	0.021	0.037	0.001		74.97	42.34	26	50	152
Normalized to (Normalizado a) 930 °C			Temper to (Temple a) 650 °C			Cooled in air. (Cooled in air. (Enfri												
WEDGE DISCO	WH81432	ASTM A-217/CA15	0.123	0.797	0.026	0.005	0.814	0.089	13.600	0.014	0.025	0.003		99.47	21.78	28	45	300
Normalized a (Normalizado to) 970 °C			Temple a (Temper to) 630 °C			Enfriado en aire. (Enfriado en aire. (C)												

PLEASA ANAHUAC Y CIAS. S.A. DE C.V.
CONTROL DE CALIDAD
FECHA 27 Ene 2010
FIRMA CO000198
Enrique Ruiz


JESSICA GARCIA