

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

(ACCORDING TO EN10204 TYPE 3.1)

ASEGURAMIENTO DE CALIDAD CERTIFICADO DE CUMPLIMIENTO

WE CERTIFY THAT THE PRODUCT LISTED BELOW WAS DESIGNED, MANUFACTURED AND TESTED ACCORDING TO OUR QUALITY SYSTEM AND REQUIREMENTS GIVEN IN ONE OR MORE OF THE FOLLOWING STANDARDS LAST EDITION

(CERTIFICAMOS QUE EL PRODUCTO LISTADO ABAJO FUE DISEÑADO, FABRICADO Y PROBADO DE ACUERDO CON NUESTRO SISTEMA DE CALIDAD Y CON REQUISITOS ESTABLECIDOS EN UNO O MAS DE LOS SIGUIENTES ESTANDARES ULTIMA EDICIÓN.)

- | | |
|--|---|
| API 598 - VALVE INSPECTION AND TESTING | API 6D - PIPELINE VALVES- GATE, PLUG, BALL AND CHECK |
| API 599 - METAL PLUG VALVES- FLANGED, THREADED AND WELDING | API 600 - STEEL GATE VALVES, FLANGED AND WELDING ENDS |
| ANSI B16-10 - FACE TO FACE AND END TO END DIMENSIONS OF VALVES | ANSI B16-11 - FORGED FITTINGS, SOCKET- WELDING AND THREADED |
| ANSI B16-34 - VALVES - FLANGED, THREADED AND WELDING ENDS | API 602 - COMPACT STEEL GATE VALVES- FLANGED, THREADED, WELDING AND EXTENDED- BODY ENDS |
| MSS-SP61 - PRESSURE TESTING OF STEEL VALVES | |

Part No. AR011A05MAB790000Z
 (Código) **2" Fig. 5341 F HF WCB, API TRIM No. 5 790000**
Description CAST STEEL SWING CHECK VALVE 150 CLASS
 Descripción (VALVULA RETENCIÓN TIPO COLUMPIO DE ACERO FUNDIDO CLASE 150)

VALVE MANUFACTURED TO MEET LOW FUGITIVE EMISSION (50 PPM'S MAX) & NACE SERVICE MR-01-75 (VALVULA SUMINISTRADA CON CONTROL DE BAJAS EMISIONES FUGITIVAS 50 PPM'S MAX.) Y PARA SERVICIO NACE MR-01-75 / MR0103-2007)

PRESSURE TEST (PRUEBAS DE PRESION)	SHELL (CASCO)	BACK (SEAT)	SIDE (LADO)	
			1	2
HYDROSTATIC (PSI) (HIDROSTATICA)	450	N A	315	N A
PNEUMATIC (PSI) (NEUMATICA)			N A	N A

MECHANICAL TESTS (PROP. MECANICAS)

		CHEMICAL COMPOSITION (%)											COMPOSICIÓN QUIMICA (%)					MECHANICAL TESTS (PROP. MECANICAS)				
ITEM (PARTE)	HEAT No. (COLADA)	MATERIAL (ASTM)	C	Mn	P	S	Si	Ni	Cr	Mo	Cu	V	Cb	TENS	YIELD	ELG	RED	BHN				
BODY CUERPO	J0628	ASTM A-216/WCB	0.220	0.870	0.020	0.017	0.410	0.030	0.080	0.030	0.030	0.010		KPSI CVN@	KPSI 1ST	% 2ND	% 3RD	AVG				
COVER TAPA	J0623	ASTM A-216/WCB	Normalized (Normalizado a) 930 °C Air Cooled. (Enfriado en aire.)											86.71	43.64	32	52	163				
WEDGE DISCO	1002125	ASTM A-105N	Normalized (Normalizado a) 930 °C Temper to (Temple a) 650 °C Air Cooled. (Enfriado en aire.)											72.51	44.23	29	58	153				
			() 930 °C () 650 °C											75.50	39.60	28	48	180				

FAC10-21 REV "3"

CERTIFICADO POR:
ASEGURAMIENTO DE CALIDAD

CERTIFIED BY :
QUALITY ASSURANCE


Jessica Garcia