



Industrial de Válvulas, s.a de c.v.
 Av. de la Industria Lote 16
 Fracc. Industrial El Trébol
 C.P. 54600 Tepetzotlán
 Estado de México

NUMERO: 8877/2008
 DATE: 8 de Septiembre de 2008

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

- | | |
|-----------|--|
| MSS SP 70 | CAST IRON GATE VALVES, FLANGED AND THREADED ENDS VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS |
| MSS SP 71 | CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS |
| MSS SP 85 | CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS |


PART NBR/CODIGO: EC080DN1MRB000000F
 DESCRIPTION/DESCRIPCION: VHC 8 125 BR A126 W719F

| | |
|----------------------------|---------|
| No. DE SERIE SERIAL No. | 08C 908 |
| | |
| | |
| | |
| FACTURA/INVOICE | 00407 |

| ESPECIFICACION SPECIFICATION | P | S | RESISTENCIA A TENSION P.SI TENSIL STRENGHT P.S.I |
|---------------------------------|-------|-------|---|
| ASTM A 126 B | 0.052 | 0.108 | 33400 |

| PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI | PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI |
|--|--|
| 350 | 200 |

CERTIFIED BY:



ASEGURAMIENTO DE CALIDAD