



Industrial de Válvulas, s.a de c.v.  
 Av. de la Industria Lote 16  
 Fracc. Industrial El Trébol  
 C.P. 54600 Tepic, Jalisco  
 Estado de México.

NUMERO: 774/2008  
 DATE: 11 de Agosto de 2008

## QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED  
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS  
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS  
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

- |           |                                                                                                                                  |
|-----------|----------------------------------------------------------------------------------------------------------------------------------|
| MSS SP 70 | CAST IRON GATE VALVES, FLANGED AND THREADED ENDS<br>VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS                     |
| MSS SP 71 | CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS<br>VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS              |
| MSS SP 85 | CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS<br>VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS |

PART NBR / CODIGO: EC040DN1MRB000000F  
 DESCRIPTION / DESCRIPCION: VHC 14 125 BR A 125 NRS W719

No. DE SERIE SERIAL No.	08C 1007 1008 1012 1013
FACTURA/INVOICE	00693

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION P.SI TENSIL STRENGTH P.S.I
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:

  
 \_\_\_\_\_  
**ASEGURAMIENTO DE CALIDAD**