



**WALWORTH**<sup>®</sup>  
Since 1842

NUMBER / NUMERO: 0218/2015

DATE / FECHA: 11 de marzo de 2015

**QUALITY ASSURANCE  
CERTIFICATE OF COMPLIANCE**

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70	CAST IRON GATE VALVES, FLANGED AND THREADED ENDS VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
MSS SP 71	CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
MSS SP 85	CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

PART NBR / CODIGO: EC120DR1MRB000000Y

DESCRIPTION / DESCRIPCION: VHC 12 125 BR A126 RS W726F

No. DE SERIE SERIAL No.	15C 1467-1468

INVOICE / FACTURA: A52544

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION P.SI TENSIL STRENGHT P.S.I
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:  
CERTIFICADO POR:

FAC 10-24 REV 00