

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

| | |
|-----------|--|
| MSS SP 70 | CAST IRON GATE VALVES, FLANGED AND THREADED ENDS VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS |
| MSS SP 71 | CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS |
| MSS SP 85 | CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS |

PART NBR / CODIGO: **EC080DR1MRB000000Y**
 DESCRIPTION / DESCRIPCION: **VHC 8 125 BR A126 W726F**

| | |
|--------------------------------|--|
| No. DE SERIE SERIAL No. | 12C 12251 12252 12240 12239 12238 12237 12236 12235 12234 12233 |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

INVOICE / FACTURA: A20750

| ESPECIFICACION SPECIFICATION | P | S | RESISTENCIA A TENSION P.SI TENSIL STRENGTH P.S.I |
|---------------------------------|-------|-------|---|
| ASTM A 126 B | 0.052 | 0.108 | 33400 |

| PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI | PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI |
|--|--|
| 350 | 200 |

CERTIFIED BY: _____
 CERTIFICADO POR: _____



FAC 10-24 REV "0"