



Industrial de Válvulas, s.a de c.v.
 Av. de la Industria Lote 16
 Fracc. Industrial El Trébol
 C.P. 54600 Tepozotlán
 Estado de México.

WAL 101-12

NUMBER: 101/2012
 DATE: 23 de Enero de 2012

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70

CAST IRON GATE VALVES, FLANGED AND THREADED ENDS
 VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 71

CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS
 VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 85

CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS
 VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

PART NBR/CODIGO: **ER080DO1MRB000000F**

DESCRIPTION/DESCRIPCION: **VHR 8 125 BR A126 W928F**

No. DE SERIE SERIAL No. FACTURA/INVOICE	12R 06 - 07 - 08 - 09 - 10 - 11 - 12 - 13 - 14 - 15
	12R 16 - 17 - 18 - 19 - 20 - 21 - 22 - 23 - 24 - 25
A12354	

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION P.SI TENSIL STRENGTH P.S.I
ASTM A 128 B	0.052	0.108	33400

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:

ASEGURAMIENTO DE CALIDAD