WALWORTH®

Industrial de Válvulas, s.a de c.v.
Av. de la Industria Lote 16
Fracc. Industrial El Trébol
C.P 54600 Tepotzotlán
Estado de México.

NUMERO: 318/2009
DATE: 15/04/2009

QUALITY ASSURANCE
CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICACTION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70	CAST IRON GATE VALVES, FLANGED AND THREADED ENDS VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
MSS SP 71	CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
MSS SP 85	CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

PART NBR/CODIGO: EC040DR1MRB000000F

DESCRIPTION/DESCRIPCION: VHC 4 125 BR A126 RS W726

No. DE SERIE SERIAL No.	08C 17281 17282 17283 17284 17285 17280 17279 17278 17277 17748
	08C 17276 17305 17304 17303 17302 17301 17296 17297 17298 17749
	08C 17299 17300 17336 17337 17338 17339 17340 17345 17344 11654
	08C 17343 17342 17341 17745 17744 17743 17742 17741 17746 17747
FACTURA/INVOICE	11853

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION P.SI TENSIL STRENGHT P.S.I
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:

ASEGURAMIENTO DE CALIDAD