

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

| | |
|-----------|--|
| MSS SP 70 | CAST IRON GATE VALVES, FLANGED AND THREADED ENDS VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS |
| MSS SP 71 | CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS |
| MSS SP 85 | CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS |

PART NBR / CODIGO: **EC040DN1MRB000000N**


DESCRIPTION / DESCRIPCION: **VHC 4 125 BR A126 NRS W719F**

| | |
|--|---|
| No. DE SERIE SERIAL No. | 12C 7326 7327 7328 7329 7330 7321 7322 7323 7324 7325 |
| | 12C 7174 7173 7172 7171 7170 7169 7168 7167 7166 7165 |
| | 12C 7345 7346 7347 7348 7349 7354 7353 7352 7351 7357 |
| | 12C 7336 7335 7334 7333 7332 7339 7340 7341 7342 7343 |
| | 12C 7235 7209 7208 7207 7206 7229 7216 7217 |
| | |
| INVOICE / FACTURA: A23459 | |

| | | | |
|---------------------------------|-------|-------|---|
| ESPECIFICACION SPECIFICATION | P | S | RESISTENCIA A TENSION P.SI TENSIL STRENGHT P.S.I |
| ASTM A 126 B | 0.052 | 0.108 | 33400 |

| | |
|--|--|
| PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI | PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI |
| 350 | 200 |

CERTIFIED BY:
CERTIFICADO POR:



FAC 10-24 REV "0"