

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

| | |
|-----------|--|
| MSS SP 70 | CAST IRON GATE VALVES, FLANGED AND THREADED ENDS VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS |
| MSS SP 71 | CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS |
| MSS SP 85 | CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS |

PART NBR / CODIGO: EC060DN1MRB000000N

DESCRIPTION / DESCRIPCION: VHC 6 125 BR A126 NRS W719F

| | |
|------------------------------------|--|
| No. DE SERIE SERIAL No. | 12C 8302 8303 8304 8305 8301 8300 10003 10031 10005 7774 |
| | 12C 1002 10006 8276 8277 7773 10596 10603 10601 10584 10585 |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

INVOICE / FACTURA: A23459

| ESPECIFICACION SPECIFICATION | P | S | RESISTENCIA A TENSION P.SI TENSIL STRENGHT P.S.I |
|---------------------------------|-------|-------|---|
| ASTM A 126 B | 0.052 | 0.108 | 33400 |

| PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI | PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI |
|--|--|
| 350 | 200 |

CERTIFIED BY: _____
 CERTIFICADO POR: _____

