



Industrial de Válvulas, s.a de c.v.  
 Av. de la Industria Lote 16  
 Fracc. Industrial El Trébol  
 C.P. 54600 Tepozotlán  
 Estado de México.

NUMERO: 547/2009  
 DATE: 03/07/2009

## QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED  
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS  
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS  
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70

CAST IRON GATE VALVES, FLANGED AND THREADED ENDS  
 VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 71

CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS  
 VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 85

CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS  
 VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

**PART NBR/CODIGO: EC060DN1MRB000000Y**

**VHC 6 125 BR A126 NRS W719**

|                                |   |  |  |
|--------------------------------|---|--|--|
| No. DE SERIE<br><br>SERIAL No. | 09C 3999 3998 3997 3996 4000 4001 4093 4094 4095 4096 |  |  |
|                                | 09C 4092 4109 4110 4111 4112 4114 4113 4055 4054 4053 |  |  |
|                                | 09C 4052 4050 4051 4037 4066                          |  |  |
|                                |   |  |  |
|                                |   |  |  |
|                                |   |  |  |
|                                |   |  |  |
|                                |   |  |  |
|                                |   |  |  |
|                                |   |  |  |
| FACTURA/INVOICE                | <b>16047</b>  |  |  |

| ESPECIFICACION<br>SPECIFICATION | P     | S     | RESISTENCIA A TENSION P.SI<br>TENSIL STRENGHT P.S.I |
|---------------------------------|-------|-------|---|
| ASTM A 126 B                    | 0.052 | 0.108 | 33400   |

| PRUEBA CASCO PSI<br>HYDROSTATIC SHELL TEST PSI | PRUEBA SELLO PSI<br>HYDROSTATIC SEAT TEST IN PSI |
|--|--|
| 350  | 200  |

CERTIFIED BY:

  


---

**ASEGURAMIENTO DE CALIDAD**