



Industrial de Válvulas, s.a de c.v.  
 Av. de la Industria Lote 16  
 Fracc. Industrial El Trébol  
 C.P. 54600 Tepetzotlán  
 Estado de México.

NUMERO: 548/2009  
 DATE: 06/07/2009

## QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED  
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS  
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS  
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70

CAST IRON GATE VALVES, FLANGED AND THREADED ENDS  
 VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 71

CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS  
 VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 85

CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS  
 VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

**PART NBR/CODIGO: EC100DR1MRB000000F**


**VHC 10 125 BR A126 RS W726**

No. DE SERIE  SERIAL No.	08C 15443 15442 15441 18979 18977 18978 18982 18980 18981 18962									
FACTURA/INVOICE	16212									

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION P.SI TENSIL STRENGTH P.S.I
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:

  
 \_\_\_\_\_  
**ASEGURAMIENTO DE CALIDAD**