WALWORTH®

Industrial de Válvulas, s.a de c.v.
Av. de la Industria Lote 16
Fracc. Industrial El Trébol
C.P. 54600 Tepotzotlán
Estado de México.

NUMERO: 572/2009
DATE: 08/07/2009

QUALITY ASSURANCE
CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICACTION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70	CAST IRON GATE VALVES, FLANGED AND THREADED ENDS VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
MSS SP 71	CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
MSS SP 85	CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

PART NBR/CODIGO: EC060DR1MRB000000Y

VHC 6 125 BR A126 W726F

No. DE SERIE SERIAL No.	08C 13761 13760 13759 13758 13757, 09C 4642 4643 4644 4645 4641
	09C 4602 4696 4600 4601 2478 4698 4605 4632 4631 2480
	09C 4604 4603 4697 4699 2476 4616 2498 4635 2477 2479
	09C 3692 3712 3711 3710 3709 3708 4585 4584 4583 4582
	09C 4581 4586 4587 4588 4589 4590
FACTURA/INVOICE	16326

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION P.SI TENSIL STRENGHT P.S.I
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:

ASEGURAMIENTO DE CALIDAD