



Industrial de Valvulas, s a de cv
 Av. de la Industria Lone 16
 Fracc. Industrial El Trebol
 C.P. 54600 Tepic, Jalisco
 Estado de Mexico

NUMERO: 677/2009
 DATE: 19/08/2009

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

- | | |
|-----------|--|
| MSS SP 70 | CAST IRON GATE VALVES, FLANGED AND THREADED ENDS
VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS |
| MSS SP 71 | CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS
VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS |
| MSS SP 85 | CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS
VALVULA DE GLOBO Y ANGULO DE HIERRO. EXTREMOS BRIDADOS Y ROSCADOS |

PART NBR/CODIGO: ER030DO1MRB000000Y

DESCRIPTION/DESCRIPCION: VHR 3 125 BR A126 W928F

No. DE SERIE SERIAL No.	09R 2340 2339 2338 2337 2332 2331 2336		
FACTURA/INVOICE	16774		

ESPECIFICACION	P	S	RESISTENCIA A TENSION P.SI
SPECIFICATION			TENSIL STRENGTH P.S.I
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI	PRUEBA SELLO PSI
HYDROSTATIC SHELL TEST PSI	HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:

 ASEGURAMIENTO DE CALIDAD