



Industrial de Válvulas, s.a de c.v.
 Av. de la Industria Lote 16
 Fracc. Industrial El Trébol
 C.P. 54600 Tapacholán
 Estado de México

NUMERO: 190/2010
 DATE: 26 de Marzo de 2010

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70

CAST IRON GATE VALVES, FLANGED AND THREADED ENDS
 VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 71

CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS
 VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 85

CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS
 VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

PART NBR/CODIGO: ER080D01MRB000000F

DESCRIPTION/DESCRIPCION: VHR 8 125BR A126 W928

	10R 2197 2196
No. DE SERIE	
SERIAL No.	
	<div style="border: 2px solid black; padding: 5px; width: fit-content; margin: auto;"> <p style="text-align: center; margin: 0;">PLEASA ANAHUAC Y CIA.S. S.A. DE C.V.</p> <p style="text-align: center; margin: 0;">CONTROL DE CALIDAD</p> <p style="text-align: center; margin: 0;">FECHA <u>26 Mar 2010</u></p> <p style="text-align: center; margin: 0;"><u>ES72</u></p> <p style="text-align: center; margin: 0;">FIRMA <u>E. RUIZ</u></p> </div>
FACTURA/INVOICE	123188

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION P.S.I TENSIL STRENGTH P.S.I
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:

 ASEGURAMIENTO DE CALIDAD