



Industrial de Válvulas, s.a de c.v.  
 Av. de la Industria Lote 18  
 Fracc. Industrial El Trébol  
 C.P. 54600 Tepic, Jalisco  
 Estado de México.

NUMERO: 192/2010  
 DATE: 26 de Marzo de 2010

## QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED  
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS  
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS  
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70	CAST IRON GATE VALVES, FLANGED AND THREADED ENDS VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
MSS SP 71	CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
MSS SP 85	CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

**PART NBR/CODIGO: ER030DO1MRB000000Y**

**DESCRIPTION/DESCRIPCION: VHR 3 125 BR A126 W928F**

No. DE SERIE  SERIAL No.	10C 2091 2090 2083 2084 2085
FACTURA/INVOICE	123507

PLEASA ANAHUAC Y CIA. S.A. DE C.V.

CONTROL DE CALIDAD

FECHA 26 Mar 2010  
ES70

FIRMA E. RUIZ

ESPECIFICACION	P	S	RESISTENCIA A TENSION P.SI
SPECIFICATION			TENSIL STRENGTH P.SI
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI	PRUEBA SELLO PSI
HYDROSTATIC SHELL TEST PSI	HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:

\_\_\_\_\_  
**ASEGURAMIENTO DE CALIDAD**