



Industrial de Válvulas, S.A. de C.V.  
 Av. de la Industria, Lote 16  
 Fracc. Industrial El Trébol  
 C.P. 54800 Tapacholán  
 Estado de México

NUMERO: 206/2010  
 DATE: 31 de Marzo de 2010

## QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED  
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS  
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS  
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70

CAST IRON GATE VALVES, FLANGED AND THREADED ENDS  
 VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 71

CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS  
 VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 85

CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS  
 VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

**PART NBR/CODIGO: EC100DN1MRB000000F**

**DESCRIPTION/DESCRIPCION: VHC 10 125 BR A126 W719F**

No. DE SERIE  SERIAL No.	10C 3274 3272		
FACTURA/INVOICE	123568	<div style="border: 2px solid black; padding: 5px; width: fit-content; margin: auto;"> <p style="text-align: center; margin: 0;"><b>PLEASA ANAHUAC Y CIA. S.A. DE C.V.</b></p> <p style="text-align: center; margin: 0;"><b>CONTROL DE CALIDAD</b></p> <p style="margin: 0;">FECHA <u>31 Mar 2010</u></p> <p style="margin: 0; margin-left: 100px;"><u>ESQ</u></p> <p style="margin: 0;">FIRMA <u>E. RUIZ</u></p> </div>	

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION P.SI TENSILE STRENGTH P.SI
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:

\_\_\_\_\_  
**ASEGURAMIENTO DE CALIDAD**