WALWORTH®

Industrial de Válvulas, s.a de c.v.
Av. de la Industria Lote 16
Fracc. Industrial El Trébol
C.P. 54600 Tepotzotlán
Estado de México.

**NUMBER: 262/2011**
**DATE: 18 de Abril de 2011**

# QUALITY ASSURANCE
# CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICACTION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

| | |
|---|---|
| MSS SP 70 | CAST IRON GATE VALVES, FLANGED AND THREADED ENDS<br>VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS |
| MSS SP 71 | CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS<br>VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS |
| MSS SP 85 | CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS<br>VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS |

**PART NBR/CODIGO: EC040DR1MRB000000Y**

**DESCRIPTION/DESCRIPCION: VHC 4 125 BR A126 RS W726**

| | |
|---|---|
| | 11C 784 783 782 781 780 779 778 777 776 775 |
| No. DE SERIE | 11C 790 791 792 793 794 789 788 787 786 785 |
| SERIAL No. | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| FACTURA/INVOICE | A3165 |

| ESPECIFICACION SPECIFICATION | P | S | RESISTENCIA A TENSION P.SI TENSIL STRENGHT P.S.I |
|---|---|---|---|
| ASTM A 126 B | 0.052 | 0.108 | 33400 |

| PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI | PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI |
|---|---|
| 350 | 200 |

CERTIFIED BY:

ASEGURAMIENTO DE CALIDAD

FAC 10-24 REV "0"