



Industria de VALVES, S.A. de C.V.
 Av. de la Industria Lot 16
 Fracc. Industrial El Tribol
 C.P. 54600 Tepic, Jalisco
 Estado de México

NUMERO: 269/2010
 DATE: 22 de Abril de 2010

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

- | | |
|-----------|--|
| MSS SP 70 | CAST IRON GATE VALVES, FLANGED AND THREADED ENDS
VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS |
| MSS SP 71 | CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS
VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS |
| MSS SP 85 | CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS
VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS |

PART NBR/CODIGO: EC040DN1MRB000000Y

DESCRIPTION/DESCRIPCION: VHC 4 125 BR A126 NRS W719

No. DE SERIE	10C 3894 3895 3896		
SERIAL No.			
FACTURA/INVOICE	124132		

PLEASA ANAHUAC Y CIA. S.A. DE C.V.

CONTROL DE CALIDAD

FECHA 23 Abr 2010
E.654

FIRMA E. RUIZ

ESPECIFICACION	P	S	RESISTENCIA A TENSION P.S.I
SPECIFICATION			TENSILE STRENGTH P.S.I
ASTM A 126 B	0.052	0.108	62400

PRUEBA CASCO PSI	PRUEBA SELLO PSI
HYDROSTATIC SHELL TEST PSI	HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:

 ASEGURAMIENTO DE CALIDAD