



Industrial de Válvulas, s.a de c.v.
 Av. de la Industria Lote 16
 Fracc. Industrial El Trébol
 C.P. 54600 Tepic, Jalisco
 Estado de México.

NUMERO:286/2008
 DATE:14/04/08

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70	CAST IRON GATE VALVES, FLANGED AND THREADED ENDS VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
MSS SP 71	CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
MSS SP 85	CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

PART NBR / CODIGO: EC120DR1MRB
 DESCRIPTION / DESCRIPCION: VHC 12 125 BR A 126 W726

No. DE SERIE SERIAL No.	08C 192 198 196 197 193 191
FACTURA/INVOICE	93798

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION P.SI TENSIL STRENGTH P.S.I
ASTM A 128 B	0.052	0.108	33400

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:

ASEGURAMIENTO DE CALIDAD