



Industrial de Válvulas, S.A. de C.V.  
 Av. de la Industria Lote 16  
 Fracc. Industrial El Tribol  
 C.P. 54600 Tepic, Jalisco  
 Estado de México

NUMERO:297/2008  
 DATE:15/04/08

## QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED  
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS  
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS  
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

- |           |  |
|-----------|--|
| MSS SP 70 | CAST IRON GATE VALVES, FLANGED AND THREADED ENDS<br>VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS                     |
| MSS SP 71 | CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS<br>VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS              |
| MSS SP 85 | CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS<br>VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS |

PART NBR / CODIGO: EC040DR1MRB  
 DESCRIPTION / DESCRIPCION: VHC 4 125 BR A 126 RS W726

No. DE SERIE SERIAL No.	08C 6545 6546 6542 6541 6552 6540 6543 6544 6539 6538 6557 6558 6560 6549 6548 6561 6553 6547 6550 6551 7071 6573 6582 6633 6634 6635 6636 6637 6658 6638
FACTURA/INVOICE	94048

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION P.SI TENSIL STRENGHT P.SI
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:   
 \_\_\_\_\_  
 ASEGURAMIENTO DE CALIDAD