



Industrial de Válvulas, s.a de c.v.  
 Av. de la Industria Loto 16  
 Fracc. Industrial El Trébol  
 C.P. 54600 Tepetzotlán  
 Estado de Méxco.

NUMBER: 320/2012  
 DATE: 21 de Marzo de 2012

## QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED  
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS  
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS  
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70	CAST IRON GATE VALVES, FLANGED AND THREADED ENDS VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
MSS SP 71	CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
MSS SP 85	CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

PART NBR/CODIGO: **EG030DR1MRB000000Y**

DESCRIPTION/DESCRIPCION: **VHG 3 125 BR A126 RS W906**

No. DE SERIE  SERIAL No.	12G 61 62 63 64 65 66 67 68 69 70		
FACTURA/INVOICE	<b>A14714</b>		

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION P.SI TENSIL STRENGHT P.S.I
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:

\_\_\_\_\_  
**ASEGURAMIENTO DE CALIDAD**