



Industrial de Válvulas, s.a de c.v.  
 Av. de la Industria Lote 16  
 Fracc. Industrial El Trébol  
 C.P. 54600 Tepotzotlán  
 Estado de México.

**NUMBER: 325/2011**  
**DATE: 18 de Mayo de 2011**

**QUALITY ASSURANCE  
 CERTIFICATE OF COMPLIANCE**

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED  
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS  
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS  
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70

CAST IRON GATE VALVES, FLANGED AND THREADED ENDS  
 VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 71

CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS  
 VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 85

CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS  
 VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

**PART NBR/CODIGO: ER100DO1MRB000000F**

**DESCRIPTION/DESCRIPCION: VHR 10 125 BR A126 W928F**

No. DE SERIE  SERIAL No.	11R 2019	
FACTURA/INVOICE	A4074	

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION P.SI TENSIL STRENGTH P.S.I
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:

  
 \_\_\_\_\_  
**ASEGURAMIENTO DE CALIDAD**