



Industrial de Válvulas, S.A. de C.V.  
 Av. de la Industria Lote 16  
 Fracc. Industrial El Trébol  
 C.P. 54600 Tepic, Jalisco  
 Estado de México.

NUMERO: 403/2010  
 DATE: 14 de Julio de 2010

## QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70

CAST IRON GATE VALVES, FLANGED AND THREADED ENDS  
 VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 71

CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS  
 VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 85

CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS  
 VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

**PART NBR/CODIGO: EG040DR1MRB000000F**

**DESCRIPTION/DESCRIPCION: VHG 4 125 BR A126 R5 W906**

No. DE SERIE  SERIAL No.	10G 1102 1103 1106 1105 1104 1107
FACTURA/INVOICE	126269

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION TENSIL STRENGTH P.S.I.
ASTM A 126 B	0.052	0.108	3340

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

PLEASA ANAHUAC Y CIA. S.A. DE C.V.

CONTROL DE CALIDAD

FECHA 14 Julio 2010

E115

FIRMA E. RUIZ

CERTIFIED BY:

\_\_\_\_\_  
**ASEGURAMIENTO DE CALIDAD**