



Industrial de Válvulas, s.a de c.v.
 Av. de la Industria Lote 18
 Fracc. Industrial El Trébol
 C. P. 54600 Tepotzotlán
 Estado de México.

NUMERO: 409/2010
 DATE: 14 de Julio de 2010

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70

CAST IRON GATE VALVES, FLANGED AND THREADED ENDS
 VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 71

CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS
 VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 85

CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS
 VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

PART NBR/CODIGO: ER080DO1MRB000000F

DESCRIPTION/DESCRIPCION: VHR 8 125 BR A126 W928

No. DE SERIE SERIAL No.	10R 2549 2548 2551 2550 2553 2552 2555 2554 2556 2557
FACTURA/INVOICE	126270

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION P.SI TENSIL STRENGTH P.S.I
ASTM A 126 B	0.052	0.108	334

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

PLEASA ANAHUAC Y CIA. S.A. DE C.V.

CONTROL DE CALIDAD

FECHA 14 Julio 2010

E1112

FIRMA E. RUIZ

CERTIFIED BY:

 ASEGURAMIENTO DE CALIDAD