



Industrial de Válvulas, S.A. de C.V.
 Av. de la Industria Lot 16
 Fracc. Industrial El Trébol
 C.P. 54600 Tepozotlán
 Estado de México.

NUMERO: 422/2010
 DATE: 20 de Julio de 2010

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

- MSS SP 70 CAST IRON GATE VALVES, FLANGED AND THREADED ENDS
VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
- MSS SP 71 CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS
VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
- MSS SP 85 CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS
VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

PART NBR/CODIGO: EC040DR1MRB000000Y

DESCRIPTION/DESCRIPCION: VHC 4 125 BK A126 RS W726

No. DE SERIE SERIAL No.	10- 5062 5098 5065 5075 5070 4992 4991 4990 4987 4989
FACTURA/INVOICE	126796

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION PSI TENSIL STRENGTH P.S.I
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

PLEASA ANAHUAC Y CIA. S.A. DE C.V.
CONTROL DE CALIDAD
 FECHA 20 Julio 2010
 FIRMA E. RUIZ

CERTIFIED BY:

ASEGURAMIENTO DE CALIDAD