



Industrial de VALVULAS, S.A. de C.V.  
 Av. de la Industria Lote 16  
 Fracc. Industrial El Trébol  
 C.P. 54600 Topotzotlán  
 Estado de México

NUMERO: 430/2010  
 DATE: 21 de Julio de 2010

## QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED  
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS  
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS  
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70

CAST IRON GATE VALVES, FLANGED AND THREADED ENDS  
 VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 71

CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS  
 VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 85

CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS  
 VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

PART NBR/CODIGO: EC060DN1MRB000000Y

DESCRIPTION/DESCRIPCION: VHC 6 125 BR A126 NRS W719

No. DE SERIE  SERIAL No.	10C 5218 5217 5228 5227 5226 5225 5229 5230 5209 5208
	10C 5207 5206 5204 5205 5203 5202 5201 5198 5199 5200
FACTURA/INVOICE	126833

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION P.S.I. TENSIL STRENGTH P.S.I.
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

**PLEASA ANAHUAC Y CIA. S.A. DE C.V.**

**CONTROL DE CALIDAD**

FECHA 21 Julio 2010  
 E1122

FIRMA E. RUIZ

CERTIFIED BY:

\_\_\_\_\_  
**ASEGURAMIENTO DE CALIDAD**