

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70

CAST IRON GATE VALVES, FLANGED AND THREADED ENDS
VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 71

CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS
VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 85

CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS
VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

PART NBR/CODIGO: EC100DN1MRB000000F
DESCRIPTION/DESCRIPCION: VHC 10 125 BR A126 W719F

| | |
|--|--------------|
| No. DE SERIE SERIAL No. | 11C 2322 |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| FACTURA/INVOICE | A5370 |

| ESPECIFICACION SPECIFICATION | P | S | RESISTENCIA A TENSION P.SI TENSIL STRENGHT P.S.I |
|---------------------------------|-------|-------|---|
| ASTM A 126 B | 0.052 | 0.108 | 33400 |

| PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI | PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI |
|--|--|
| 350 | 200 |

CERTIFIED BY:



ASEGURAMIENTO DE CALIDAD