



Industrial de Válvulas, s.a de c.v.  
 Av. de la Industria Lote 16  
 Fracc. Industrial El Trébol  
 C.P. 54600 Tepic, Jalisco  
 Estado de Jalisco.

NUMBER: 049/2011  
 DATE: 20 de Enero de 2011

## QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED  
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS  
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS  
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70

CAST IRON GATE VALVES, FLANGED AND THREADED ENDS  
 VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 71

CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS  
 VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 85

CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS  
 VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

**PART NBR/CODIGO: ER060DO1MRB000000F**

**DESCRIPTION/DESCRIPCION: VHR 6 125 BR A126 W928**

|                                |          |
|--------------------------------|----------|
| No. DE SERIE<br><br>SERIAL No. | 10R 2626 |
|                                |          |
|                                |          |
|                                |          |
|                                |          |
|                                |          |
|                                |          |
|                                |          |
|                                |          |
|                                |          |
| FACTURA/INVOICE                | A445     |

| ESPECIFICACION<br>SPECIFICATION | P     | S     | RESISTENCIA A TENSION P.SI<br>TENSIL STRENGTH P.S.I |
|---------------------------------|-------|-------|---|
| ASTM A 126 B                    | 0.052 | 0.108 | 33400   |

| PRUEBA CASCO PSI<br>HYDROSTATIC SHELL TEST PSI | PRUEBA SELLO PSI<br>HYDROSTATIC SEAT TEST IN PSI |
|--|--|
| 350  | 200  |

CERTIFIED BY:

  


---

**ASEGURAMIENTO DE CALIDAD**