



Industrial de Válvulas, s.a de c.v.  
 Av. de la Industria Lote 18  
 Fracc. Industrial El Trébol  
 C.P. 54600 Tepic, Jalisco  
 Estado de México

NUMERO: 494/2010  
 DATE: 11 de Agosto de 2010

## QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED  
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS  
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS  
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

- |           |  |
|-----------|--|
| MSS SP 70 | CAST IRON GATE VALVES, FLANGED AND THREADED ENDS<br>VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS                     |
| MSS SP 71 | CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS<br>VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS              |
| MSS SP 85 | CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS<br>VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS |

**PART NBR/CODIGO: EC100DN1MR800000F**

**DESCRIPTION/DESCRIPCION: VHC 10 125 BR A126 W719F**

	<b>10C 5623 5619 5620 5494 5495</b>
No. DE SERIE	
SERIAL No.	
FACTURA/INVOICE	<b>127600</b>

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION P.SI TENSIL STRENGTH P.S.I
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:

  
 \_\_\_\_\_  
**ASEGURAMIENTO DE CALIDAD**