


CERTIFIED BY:

ASEGURAMIENTO DE CALIDAD



PRUEBA CASCO PSI	350
HYDROSTATIC SHELL TEST PSI	
PRUEBA SELLO PSI	200
HYDROSTATIC SEAT TEST IN PSI	

ESPECIFICACION	P	0.052	0.108	33400
ASTM A 126 B				
TENSIL STRENGTH P.S.I	S			
RESISTENCIA A TENSION P.S.I				

FACTURA/INVOICE	4949
SERIAL NO.	
No. DE SERIE	08C 18486 18487 18488 18489 18490 18491 18492 18493 18494 18495 08C 18496 18497 18498 18499 18500 18501 18502 18503 18504 18505 08C 18506 18507 18508 18509 18462 18463 18464 18465 18466 18467

PART NBR/CODIGO: EC010DN1MRB000000Y
DESCRIPTION/DESCRIPCION: VHC 2 125 BR A126 NRS W719

- MSS SP 85 CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS
VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS
- MSS SP 71 CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS
VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
- MSS SP 70 CAST IRON GATE VALVES, FLANGED AND THREADED ENDS
VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS Y PRBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

**QUALITY ASSURANCE
CERTIFICATE OF COMPLIANCE**



Industrial de Villavieja, s.a de c.v.
Av. de la Industria Lote 16
Frac. Industrial El Trebol
C.P. 54600 Tepozotlan
Estado de Mexico.

NUMERO: 1124/2008
DATE: 24/11/2008