



Industrial de Válvulas, s.a de cv
 Av. de la Industria Loe 16
 Fracc. Industrial El Triébol
 C.P. 54800 Tepozotlán
 Estado de México

NUMERO: 029/2009
 DATE: 22/01/2009

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

- MSS SP 70 CAST IRON GATE VALVES, FLANGED AND THREADED ENDS
VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
- MSS SP 71 CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS
VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
- MSS SP 85 CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS
VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

PART NBR/CODIGO: EC030DN1MRB000000Y
 DESCRIPTION/DESCRIPCION: VHC 3 125 BR A126 NRS W719

No. DE SERIE	08C 12499	
SERIAL No.		
FACTURA/INVOICE	5216	

ESPECIFICACION	P	S	RESISTENCIA A TENSION P.SI
SPECIFICATION			TENSIL STRENGHT P.S.I
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI	PRUEBA SELLO PSI
HYDROSTATIC SHELL TEST PSI	HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:



 ASEGURAMIENTO DE CALIDAD