WALWORTH®

Industrial de Válvulas, s.a de c.v.
Av. de la Industria Lote 16
Fracc. Industrial El Trébol
C.P. 54600 Tepotzotlán
Estado de México.

NUMBER: 578/2012
DATE: 21 de Junio de 2012

QUALITY ASSURANCE
CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICACTION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70	CAST IRON GATE VALVES, FLANGED AND THREADED ENDS VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
MSS SP 71	CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
MSS SP 85	CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

PART NBR/CODIGO: **ER060DO1MRB000000N**

DESCRIPTION/DESCRIPCION: **VHR 6 125 BR A126 W928F**

	12R 2229 1426 2227 2228 2236 2237 2234 2231 2239 2238
No. DE SERIE	12R 2233 2232 2587 2588 2589 2590 2591 2592 2593 2594
SERIAL No.	12R 2595 2596 2567 2566 2564 2575 2561 2565 2569 2570
	12R 2568 2573 2572 2571 2574 2576 2577 2578 2582 2579
	12R 2580 2581 2586 2585 2583 2584 2557 2560 2558 2559
FACTURA/INVOICE	A17880

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION P.SI TENSIL STRENGHT P.S.I
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:

ASEGURAMIENTO DE CALIDAD