



Industrial de Válvulas, s.a de cv.  
 Av. de la Industria Lote 16  
 Fracc. Industrial El Trébol  
 C.P. 54600 Tepic Jalisco  
 Estado de México

NUMERO: 1211/2008  
 DATE: 04/12/2008

## QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION. CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS Y A LOS REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70	CAST IRON GATE VALVES, FLANGED AND THREADED ENDS
MSS SP 71	CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS
MSS SP 85	CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS
	VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
	VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS
	VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

PART NBR/CODIGO: EC120DR1MRB000000Y  
 DESCRIPTION/DESCRIPCION: VHC 12 125 BR A126 W726

08C 19057 19058 19053 19054	NO. DE SERIE
	SERIAL NO.
	FACTURA/INVOICE
	6372

ESPECIFICACION	p	S	RESISTENCIA A TENSION P.S.I
ASTM A 126 B	0.052	0.108	TENSIL STRENGTH P.S.I
PRUEBA CASCO PSI			PRUEBA SELLO PSI
HYDROSTATIC SHELL TEST PSI			HYDROSTATIC SEAT TEST IN PSI
350			200

CERTIFIED BY:

ASEGURAMIENTO DE CALIDAD