



Industrial de Valvulas S de CV
 Av. de la Industria Lora 16
 Fracc. Industrial El Trebol
 C.P. 54600 Tepic, Jalisco
 Estado de Mexico

NUMERO: 691/2009
 DATE: 20/08/2009

QUALITY ASSURANCE CERTIFICATE OF COMPLIANCE

WE CERTIFY THAT THE LISTED PRODUCT AND MATERIAL WAS MANUFACTURED, INSPECTED AND TESTED
 ACCORDING TO OUR QUALITY ASSURANCE SYSTEM AND THE REQUIREMENTS OF THE APPLICABLE SPECIFICATION

CERTIFICAMOS QUE LOS PRODUCTOS Y MATERIALES LISTADOS FUERON MANUFACTURADOS, INSPECCIONADOS
 PROBADOS DE ACUERDO CON NUESTRO SISTEMA DE ASEGURAMIENTO DE CALIDAD Y A LOS
 REQUERIMIENTOS DE LAS ESPECIFICACIONES APLICABLES

MSS SP 70

CAST IRON GATE VALVES, FLANGED AND THREADED ENDS

MSS SP 71

VALVULA COMPUERTA DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

MSS SP 85

CAST IRON SWING CHECK VALVES, FLANGED AND THREADED ENDS

VALVULA RETENCION DE HIERRO EXTREMOS BRIDADOS Y ROSCADOS

CAST IRON GLOBE AND ANGLE VALVES, FLANGED AND THREADED ENDS

VALVULA DE GLOBO Y ANGULO DE HIERRO, EXTREMOS BRIDADOS Y ROSCADOS

PART NBR/CODIGO: EC040DN1MRB000000Y

DESCRIPTION/DESCRIPCION: VHC 4 125 BR A126 NRS W719

No. DE SERIE SERIAL No.	09C 1894
FACTURA/INVOICE	11853

ESPECIFICACION SPECIFICATION	P	S	RESISTENCIA A TENSION P.S.I TENSIL STRENGTH P.S.I
ASTM A 126 B	0.052	0.108	33400

PRUEBA CASCO PSI HYDROSTATIC SHELL TEST PSI	PRUEBA SELLO PSI HYDROSTATIC SEAT TEST IN PSI
350	200

CERTIFIED BY:

 ASEGURAMIENTO DE CALIDAD