


Sales Agent: ArcelorMittal Int North America 1 South Dearborn, 13th floor CHICAGO IL 60603 USA		ArcelorMittal Belval & Differdange Service Gestion Qualité 66, rue de Luxembourg L-4009 Esch/Alzette		 ArcelorMittal																																	
Plant: ArcelorMittal Belval & Differdange Site de Differdange L-4503 Differdange, LUXEMBOURG		Certificate Nr X 3495399 Delivery note number 3495399 from 20 April 2017																																			
Our reference : 1700024571		Plesa Anahuac Y Cias, S.A. de C.V. Av. Valle de las Alamedas 66-O 54940 COL. S. FRANCISCO CHILPAN, TULTI MEXICO																																			
Your reference : 25174 06.03.2017 Plesa Anahuac Y Cias, S.A. de C.V.																																					
ASTM A992 - ASTM A572 GR50 FINE GRAIN SILICON KILLED HOT ROLLED CARBON STEEL WIDE FLANGE BEAMS																																					
Manufacturer's test certificate acc. to ASTM A 6																																					
<table border="1"> <thead> <tr> <th>Ord.item</th> <th>Product</th> <th>Length</th> <th>Weight</th> <th>Heat nr</th> <th>Weight</th> <th>Bund.</th> <th>Bars</th> </tr> </thead> <tbody> <tr> <td>000003</td> <td>W 27 X 10 X 84</td> <td>40'</td> <td>6,096 kg</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td>12.192 mm</td> <td></td> <td>42600</td> <td>1,524 kg</td> <td></td> <td>1</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td>42602</td> <td>4,572 kg</td> <td></td> <td>3</td> </tr> </tbody> </table>						Ord.item	Product	Length	Weight	Heat nr	Weight	Bund.	Bars	000003	W 27 X 10 X 84	40'	6,096 kg							12.192 mm		42600	1,524 kg		1					42602	4,572 kg		3
Ord.item	Product	Length	Weight	Heat nr	Weight	Bund.	Bars																														
000003	W 27 X 10 X 84	40'	6,096 kg																																		
		12.192 mm		42600	1,524 kg		1																														
				42602	4,572 kg		3																														
Heat nr		Heat analysis (%)																																			
		C	Mn	P	S	Si	N	Cu	Ni	Cr	V	Nb	Mo	Ti	CEV	Sn	Nb+V																				
Min		0,50		0,10																																	
Max		0,23	1,60	0,035	0,045	0,40		0,60	0,45	0,35	0,150	0,050	0,150		0,45		0,150																				
42600		0,07	1,23	0,025	0,020	0,17	0,010	0,33	0,15	0,10	0,054	0,001	0,030	0,001	0,34	0,02	0,055																				
42602		0,08	1,24	0,025	0,022	0,19	0,011	0,25	0,13	0,11	0,054	0,001	0,030	0,001	0,35	0,02	0,055																				
Heat nr		Tensile test																																			
		PSI	PSI 200 mm																																		
		Ye	UTS	El. (%)	Y/U																																
Min		50.000	65.000	18,00																																	
Max		65.000	0,85																																		
42600		63.075	75.110	26,84	0,84																																
42600		64.670	76.125	23,27	0,85																																
42602		64.235	79.025	23,91	0,81																																
42602		62.495	76.415	25,05	0,82																																
Material melted and manufactured in LUXEMBOURG Customer ref : 000003 : SIHOMARA SER																																					
Klecker Roberto Porteur de signature spéciale 