



US-ML-PETERSBURG
25801 HOFHEIMER WAY
PETERSBURG, VA 23803
USA

CERTIFIED MATERIAL TEST REPORT

CUSTOMER SHIP TO GERDAU-CORSA S A P I DE CV EX RENAULT ESTACION HB22 8385 CIUDAD DE PRAY BERNARDINO,HGO 43990 Mexico		CUSTOMER BILL TO GERDAU CORSA S A P I DE CV CARRETERA MEXICO CD SAHAGUN SN CD SAHAGUN,HGO 43990 Mexico		GRADE 992/572-50	SHAPE / SIZE Wide Flange Beam / 27 X 84# / 690 X 125	
SALES ORDER 377141/000190		CUSTOMER MATERIAL Nº		LENGTH 40'00"	WEIGHT 10,080 LB	HEAT / BATCH 60104847/06
CUSTOMER PURCHASE ORDER NUMBER 4500737833		BILL OF LADING 1330-0000022899		DATE 16.07.2013		SPECIFICATION / DATE or REVISION A572/A572M-07 A992/A992M-11 ASTM A5/A5M-11

CHEMICAL COMPOSITION												
C %	Mn %	P %	S %	Si %	Cu %	Ni %	Cr %	Mo %	Sa %	V %	Nb %	Al %
0.09	1.13	0.015	0.030	0.23	0.28	0.12	0.25	0.028	0.016	0.003	0.017	0.003

CHEMICAL COMPOSITION	
CEqvA6 %	
0.3	

MECHANICAL PROPERTIES						
YS KSI	UTS KSI	YS MPa	UTS MPa	G/L Inch	G/L mm	
56.3	72.7	388	501	8.000	200.0	
54.9	72.0	379	496	8.000	200.0	

MECHANICAL PROPERTIES	
Elong. %	Y/T rati %
25.70	0.774
27.40	0.762

COMMENTS / NOTES

The above figures are certified chemical and physical test records as contained in the permanent records of company. This material, including the billets, was melted and manufactured in the USA. CMTR complies with EN 10204 3.1.

Shaskay
BHASKAR YALAMANCHILI
QUALITY DIRECTOR

Wale A. Li
WADE LUMPKINS
QUALITY ASSURANCE MGR.